

Annual Site Generation

Sites	Install Date	Predicted Yield (kWh)	Capacity (kW)	Generation (kWh)							Cumulative
				2015	2016	2017	2018	2019	2020	2021	
Grange Farm	13/02/2015	18,514	17.94	17,298	18,045	16,862	13,792 [2]	14,971	14,870	1,750	97,589
Turners Hill School	03/09/2015	13,968	16.00	2,257 [1]	12,189	11,804	10,903 [3]	11,695	12,222	1,428	62,498
Balcombe School	01/09/2015	9,163	9.75	1,659 [1]	7,864	7,535	7,782	7,638	8,085	1,148	41,711
Crawley Down School	05/04/2016	41,752	49.92		33,888 [1]	38,965 [1]	38,388	38,490 [4]	40,752	4,995	195,477
Imberhorne School	08/04/2016	46,475	49.92		36,661 [1]	41,884	41,943 [1]	41,722	43,416	4,892	210,519
Cuckfield Holy Trinity School	15/02/2018	18,555	20.52				18,726 [1]	18,386	19,419	2,434	58,964
Bridges Yard S	25/05/2020	4,594	4.83						2,873 [1]	621	3,494
Bridges Yard N	25/05/2020	15,754	16.56						9,232 [1]	1,884	11,116
Annual Totals		168,775	185.44	21,215	108,646	117,050	131,535	132,902	150,869	19,151	
Cumulative Total				21,215	129,860	246,910	378,445	511,347	662,216	681,367	681,367

[1] Installed part way through year.

[2] Damage to AC cable, no generation for May and some of June.

[3] Low generation due to inverter problem then inverter failure in April.

[4] Panels cleaned 27/4/19, but due to electrical works at school lost approx. 773kWh generation.