

Annual Site Generation

Sites	Install Date	Predicted Yield (kWh)	Capacity (kW)	Generation (kWh)						Cumulative
				2015	2016	2017	2018	2019	2020	
Grange Farm	13/02/2015	18,514	17.94	17,298	18,045	16,950	13,784 [2]	14,992	14,896	95,965
Balcombe School	01/09/2015	9,163	9.75	1,659 [1]	7,864	7,338	7,514	7,365	7,800	39,540
Turners Hill School	03/09/2015	13,968	16.00	2,128 [1]	12,188	11,920	10,903 [3]	11,741	12,221	61,101
Crawley Down School	05/04/2016	41,752	49.92		33,887 [1]	39,296 [1]	38,390	38,484 [4]	40,752	190,809
Imberhorne School	08/04/2016	46,475	49.92		36,660 [1]	42,449	41,945 [1]	41,717	43,415	206,186
Holy Trinity School	15/02/2018	18,555	20.52				18,719 [1]	18,467	19,368	56,554
Bridges Yard N	25/05/2020	15,754	16.56						9,231 [1]	9,231
Bridges Yard S	25/05/2020	4,594	4.83						2,873 [1]	2,873
Annual Totals		168,775	185.44	21,085	108,644	117,953	131,255	132,766	150,556	
Cumulative Total				21,085	129,729	247,682	378,937	511,703	662,259	659,386

[1] Installed part way through year.

[2] Damage to AC cable, no generation for May and some of June.

[3] Low generation due to inverter problem then inverter failure in April.

[4] Panels cleaned 27/4/19, but due to electrical works at school lost approx. 773kWh generation.